

From

Incharge Water Lab  
Civil Hospital  
Fatehabad

To

Medical Officer I/c  
PHC BIGER  
Fatehabad

**Subject- Results of Water sample for Coliforms.**

Sir,


With reference to subject cited above, the result of following water sample tested for bacteriological analysis is as below:-

No. WC/6/112


Date : 26.06.2024

S.No	Name of place	Source of water	Result	Remarks
1	BAL BHARTI INTERNATIONAL PUBLIC SCHOOL FATEHABAD 125050		<1 Coliform organism per 100 ml of water	Water is not contaminated & fit to use

  
LAB.TECH.

  
DR. RASEED  
LAB TIC  
In-Charge  
Department of Microbiology  
Civil Hospital Fatehabad

Note:- you are requested to kindly send the sample in clean and Sterilized bottle.

  
President  
Smt Pritam Kaur Memorial  
Education Society, Bighar  
Fatehabad

Principal   
Bal Bharti International Public School  
Affiliated to CBSE (Affi. No. 531125)  
Fatehabad-125050